


গণপ্রজাতন্ত্রী বাংলাদেশ সরকার
বাংলাদেশ পরিসংখ্যান ব্যুরো
ন্যাশনাল হাউজহোল্ড ডাটাবেইজ (এনএইচডি) প্রকল্প
পরিসংখ্যান ভবন (১০ম তলা, ব্লক-এ)
ই-২৭/এ, আগারগাঁও, ঢাকা-১২০৭।


২০/০৮/২০২৭
মিঃ আমীর হোসেন

পত্র নং: ৫২.০৩১.০০৭.০০.০০.২৩১.২০১৬- ২৬৬৬

তারিখ: ২০/০৮/২০২৭

বিষয়ঃ রিপেয়ার এন্ড মেইনটিন্যান্স অব সার্ভার রুম এন্ড আপ গ্রেডেশন অব বিবিএস ডাটা সেন্টার নির্মাণ কাজের প্রি-বিড সভার সুপারিশ প্রেরণ প্রসঙ্গে।

সূত্রঃ অত্র দপ্তরের দরপত্র আহবান বিজ্ঞপ্তি নং- ৫২.০৩১.০০৭.০০.০০.২৩১.২০১৬-১১৬৭, তারিখ: ০২/০৮/২০১৭ইং

উল্লিখিত দরপত্র আহবান বিজ্ঞপ্তির পরিপ্রেক্ষিতে বিগত ১৭/০৮/২০১৭ ইং প্রকল্প সদর দপ্তরে দরপত্রে অংশগ্রহণে আগ্রহী প্রতিষ্ঠানের প্রতিনিধিদের সাথে প্রকল্প ব্যবস্থাপনা টিমের একটি প্রি-বিড সভা অনুষ্ঠিত হয়। প্রি-বিড সভার সিদ্ধান্তসমূহ এতদসঙ্গে সংযুক্ত করে প্রয়োজনীয় ব্যবস্থা গ্রহণের জন্য প্রেরণ করা হলো।

২। প্রি-বিড সভার সিদ্ধান্তসমূহ দরপত্র দলিলের অবিচ্ছেদ্য অংশ বিধায় তা দরপত্রের সাথে দাখিল করতে হবে।

সংযুক্তঃ – প্রি-বিড সভার সিদ্ধান্ত


মোঃ আমীর হোসেন
প্রকল্প পরিচালক

বিতরণঃ

- ১। সার্ক লিমিটেড, ১৩ সি - এফ, কনকর্ড সেন্টার পয়েন্ট, ১৪/এ এবং ৩১/এ, তেজকুনিপাড়া, ফার্মগেইট, ঢাকা।
 - ২। সার্ভিস সলিউশনস প্রাইভেট লিমিটেড (এসএসএল) বিএনএস সেন্টার (৬ষ্ঠ তলা), প্লট # ৮৭, ঢাকা-ময়মনসিংহ রোড, সেক্টর # ০৭, উত্তরা, ঢাকা – ১২৩০।
 - ৩। আই.টি. কনসালট্যান্টস লিমিটেড, এভারগ্রীণ প্লাজা, ২৬০/বি, তেজগাঁও ইন্ডাস্ট্রিয়াল এরিয়া, ঢাকা – ১২০৮।
 - ৪। এনডিভোর টেকনোলজিস লিমিটেড, সুইট # ০-১১, গুলফেসা প্লাজা, ০৮ শহীদ সাংবাদিক সেলিনা পারভিন সড়ক, মগবাজার, ঢাকা- - ১২১৭।
 - ৫। টেক ভেলি সলিউশন লিমিটেড, ১৩৯, লেক সার্কাস, কলাবাগান, ঢাকা – ১২০৫।
 - ৬। স্মার্ট টেকনোলজীস (বিডি) লিমিটেড, ইয়াকুব সাউথ সেন্টার, ৬৭/ডি (পুরাতন), ১৫৬ (নতুন), মিরপুর রোড, (২য় তলা), লেক সার্কাস, কলাবাগান ঢাকা – ১২০৫।
 - ৭। কম্পটেক নেটওয়ার্ক লিমিটেড (প্রাইভেট) লিমিটেড, এপার্টমেন্ট নং: এ - ২, বাড়ী # ০৭, রোড # ১২৪, গুলশান – ১, ঢাকা – ১২১২।
- ✓ প্রোগ্রামার, ওয়েবসাইট শাখা, কম্পিউটার উইং, বাংলাদেশ পরিসংখ্যান ব্যুরো, আগারগাঁও, ঢাকা-১২০৭। (ওয়েবসাইটে প্রকাশের অনুরোধসহ)

গণপ্রজাতন্ত্রী বাংলাদেশ সরকার
 বাংলাদেশ পরিসংখ্যান ব্যুরো
 ন্যাশনাল হাউজিং অ্যান্ড ডাটা সেন্টার-এনএইচটি প্রকল্প
 পরিসংখ্যান ভবন (১০ম তলা, রক-এ)
 ই-২৭/এ, আগারগাঁও, ঢাকা-১২০৭।

Resolution of Pre-bid Meeting held on 17/04/2017 in connection with Tender for repair and maintenance of Server I and up gradation of BBS Data Center [Invitation for Tender No.- 52.031.007.00.00.231.2016-1167, Dated: 02/04/2017, Te Package # G-17]

SL No.	Name of Firm	Name and designation of representative present	Question raised	Answer of Project Auth
01	Endeavour Technologies Ltd. Suite # 0 - 11 Gulfesha Plaza, Moghbazar, Dhaka	Mr. Md. Masudur Rahman Manger Operation Mobile: 01712-758393 E-mail: service@etlbd.com	<p>I. Whether we should quote rates for serial no. 1 & 2 of the Schedule?</p> <p>II. How much quantities will be in item # 20 and # 21 of the Schedule?</p> <p>III. What will be the size of cable in item # 31 and 32 of the schedule?</p> <p>IV. What will be the back-up time of online UPS?</p>	<p>I. No.</p> <p>I. Item # 20: 75m in place 20m II. Item # 21: 75m in place 15m</p> <p>I. Item # 31: Cable size be 3 x 6 RM in place 4RM II. Item # 32: Cable size be 3 x 6 RM in place 4RM</p> <p>I. Back-up time will be minimum 1.00 (one)</p>

Masudur Rahman
 20/8/2017

[Signature]

SL No.	Name of Firm	Name and designation of representative present	Question raised	Answer of Project Authority
02	Smart Technologies (BD) Ltd. Yakub South Center 156 (New), Mirpur Road, Lake Circus, Kalabagan, Dhaka.	Mr. Sadiq Imroze Sr. Manager Mobile: 01709-642441 E-mail: sadiq.imroz@smart_bd.com	<p>I. Item # 58: what will be the cylinder capacity and what type gas we are to consider?</p> <p>II. Item # 92 of the schedule. Rosenberger is a brand name. Whether this word will remain as it is in the schedule?</p> <p>III. Item # 120, page # 123: Specification i com is a brand name. Whether it will remain as it is in the specification?</p>	<p>I. 100 litres in place of 26.5/42.2 litre. Please consider NOVEC - 12 type of gas for all purposes.</p> <p>II. Please read : Rosenberger/equivalent</p> <p>III. Instead of i com controller/equivalent please read- i com controller/equivalent</p>
03	Tech Valley Solutions Ltd. 139 Lake Circus Kalabagan, Dhaka-1205.	Mr. Md. Arif-uz Zaman Manager, Sales and Marketing Mobile: 01730-709286 E-Mail: pavel@tvs_bd.com	<p>I. Item # 121, Specification. Please change: 4(c): Nominal output voltage: 480, 3PH, 600, 3PH</p> <p>II. Item # 121, Specification. Please change: 4 (d): output Frequency (sync to mains): 60 Hz</p> <p>III. Is there any change in specification of item no. - 10?</p>	<p>I. Agreed. Please read. Nominal output voltage 400V 3PH</p> <p>II. Agreed. Please read Frequency (sync to mains) 50 Hz - 60Hz</p> <p>III. Yes. In place of anti-static HPL ventilation raised floor panel, please read Antistatic HPL ventilation calcium sulphate solid raised floor panel.</p>

[Handwritten signature]
20/02/2021

SL No.	Name of Firm	Name and designation of representative present	Question raised	Answer of Project Auth
04	SHARK LIMITED 13 C-F, Concord Center Point 14/A & 31/A, Tejkunipara, Farmgate, Dhaka.	Mr. Md. Saiful Islam Sr. Executive, Sales	<p>I. Item # 121, Specification. Please change: 4 (e), other output voltage: 208, 220V</p> <p>II. Item # 121, Specification. Please change 5(a): Nominal input voltage: 480, 3PH, 600, 3PH</p> <p>III. Item # 121, Specification. Please change 5(b): Input Frequency: 60Hz ± 5Hz</p> <p>IV. Item # 121, Specification. Please change 5(d): Input voltage range for main operation: 408-528V</p> <p>V. Item # 121, Specification. Please change 5(f): Input breaker capacity: 12:00 AM</p> <p>VI. Whether 32 inch LED Color Monitor as mentioned in item no. 90, will remain as it is?</p> <p>VII. Whether the cables are fire resistant or not?</p>	<p>I. Agreed. Please read- output voltage: 400V, 3PH</p> <p>II. Agreed. Please read- Nominal input voltage 400V, 3PH</p> <p>III. Agreed. Please read- Frequency: 50Hz - 60</p> <p>IV. Agreed. Please read- voltage range for main operation: 360-440V</p> <p>V. Agreed. Please read- breaker capacity: 12:00 AM</p> <p>VI. LED Color Monitor size will be 56 inch in of 32 inch.</p> <p>VII. All networking cables: copper cables, cat-6 cables, patch cords shall be fire redundant and 23 AWG. Doors also shall be fire rated.</p>

Signature
20/8/2021


Signature

SL No.	Name of Firm	Name and designation of representative present	Question raised	Answer of Project Auth
05	Service Solutions Pvt. Ltd. BNS Center, Sector # 04 Uttara, Dhaka-1230	Mr. Md. Rokibul Hasan Sr. Manager, IT	I. Item # 43-46: Specification. We requested to delete as per NETCOM Standard.	Agreed. Please disregard line: As per NETCOM Standard.
06	IT Consultant Ltd. Evergreen Plaza 260/B, Tejgaon I/A, Dhaka-1208.	Mr. Zubaer Ahmed Head of Transaction Processing and Business Initiatives.	I. Item # 113of the schedule (page -82 & 92) Duration of the course will be 3 (three) days or more.	The course duration will (five) days instead of 3 (t days.
07	Tech Valley Solutions Ltd. 139, Lake Circus, Kalabagan, Dhaka-1205	Mr. Md. Arifuz Zaman Manager Sales and Marketing	I. Please extend the submission date minimum 07 (seven) days. II. Please provide us soft copy of tender document	I. Not agreed. II. Agreed. To be provide within three days.
08	MS Business Solution Ltd. House No: 330, Road #:22, New DOHS, Mohakhali, Dhaka.	Mr. Masud Alam Director	I. In the specification of Online UPS under Sl. No: 06, (page: 126) Sub-head: Batteries and amp; Runtime, it is written a) Battery Type: No internal battery - uses external battery system b) Included Battery Modules: 0 c) Battery Slots Empty: 0 d) Typical recharge time hour(s) : 0 e) RBC Quantity: 0 Whether it will as it is?	I. There will be change: The bidder will propo: values of the paramet

Dommasur
20/8/2021

[Signature]

SL No.	Name of Firm	Name and designation of representative present	Question raised	Answer of Project Authority
09	Mesh Technologies Ltd. House No: 77, Level 2 and 3, Road # 2, Block - A, Bashundhara Residential Area, Dhaka-1229.	Mr. M. Abdullah Al Mamun Executive Director	<p>I. In the specification of Online UPS under SL No: 08, (Page: 126) Sub-head: Physical, it is written: a) Maximum Height 1900.0 mm b) Maximum Width: 712.0 mm c) Maximum Depth: 848.0 mm d) Rack Height: 0 U e) Net Weight: 400.0 kg f) Shipping Weight: 420.0 kg g) Shipping Height: 2032.0 mm h) Shipping Width: 978.0 mm i) Shipping Depth: 960.0 mm j) Master Carton Units: 0 k) Master Carton Weight: 0.0 Ibs l) Color: Grey m) Units per Pallet: 0 Whether it will remain as it is?</p> <p>II. Is there any change in the specification of item no. 92?</p>	<p>I. There will be change: The bidder will propose values of the parameter</p> <p>II. Yes. In place of UTP cable, (10G) cable, Rosenber should be FTP, cat 6A cable, Rosenberger/equivalent</p>


 M. M. Mamun
 20/8/2021


 Project Authority